



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 11/10/2025

Area: CHP

Equipment	Job
CC-40,CC-37	Running inspection done
STK-3	Slew drive modification completed. Slew movement checked with proper direction. Motors canopy also arranged
STK-3	Lower E-House roof work completed
STK-3	Slew drive second motor coupling fixed, mounted on base, tested with drive. made ok