



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 01/12/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc on co-28	CT NOT TAKING PLACE FOUND CONTROL MCB TRIPPED	MADE ON	13:10:00	13:20:00	
2	OHP	TBS ON CO-19	LT NOT TAKING PLACE FOUND THRUSTER BRAKE MCB TRIPPED	MADE ON THAN OK	11:20:00	11:30:00	
3	OHP	BRC ON CO-34	REPORTED B/W-1 NOT RUNNING FOUND DMPR PLUG LOOSE	FIXED PROPER THAN OK	08:00:00	08:20:00	
4	OHP	CO-68	REPORTED STOPPING ON ZSS FOUND ZSS CAGE STUCK UP AND PROBE DAMAGED	ZSS BYPASSED TEMPORARY CAGE FREE IT ZSS PROBE REPLACED WITH NEW PROBE THAN KEPT IN CIRCUIT	07:45:00	08:30:00	
5	CHP	CC-54	TRIPPED ON OLR (2TIMES)	RESET DONE	11:30:00 12:10:00	11:35:00 12:15:00	
6	CHP	CC-33 SCR-5	LUFF NOT WORKING OLR TRIP	RESET DONE	06:35:00	06:45:00	
7	CHP	CC-111 SCR-8	SIGNAL MISSING	LT MOVE F/D THAN OK	06:25:00	06:35:00	
8	CHP	CC-40 SCR-2	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED THAN OK	08:50:00	09:05:00	
9	CHP	CC-125	TRIPPED ON OLR	RESET DONE	09:45:00	09:50:00	
10	CHP	CC-201,CC-203	TRIPPED ON OLR	RESET DONE	09:50:00	09:55:00	
11	CHP	CC-111 SCR-8	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED	10:00:00	10:10:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/12/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CP-3	REPORTED NOT MOVE FOUND LC-10A I/C-2 TRIPPED	B/C CHARGED THAN OK	09:00:00	09:20:00	