



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 22/08/2025

Shift: C

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO2a	Not moving ZSS acted found ZSS probe came out	Probe fixed properly	00:23:00	00:38:00	
2	CHP	SCR5 on CC32	BC CJS new module fixed and kept in ckt	B shift problem	22:20:00	22:30:00	
3	CHP	SCR7 on CC105	LT not working found PCRD OT acted	OT limit released then ok	23:25:00	23:35:00	
4	CHP	CC107	ZSS acted found over load on belt	Informed to operation requested for local after material cleaning again placed in PLC	02:20:00	02:35:00	
5	CHP	SCR3 on CC40	Luffing not working found luffing down limit struck	Down limit released	02:40:00	02:50:00	
6	CHP	SCR9 on CC104	Slew not working found power MCCB trip	MCCB made on	04:00:00	04:15:00	
7	CHP	SCR1 on CC35	LT not working found PCRD cable zigzag and drive olr trip	Drive olr reset done and PCRD cable laid properly then ok	04:15:00	04:35:00	
8	CHP	CC51	olr acted 3 times	Reset done	23:00:00	00:30:00	
9	CHP	CC51	Feeding conveyor MPD trip 12 times due to material over load and deck sheets jamming stopping feeding conveyor	informed to operation tail end cleaning done Reset done	01:00:00	06:00:00	
10	WT	OP1	Not moving found D6 olr acted	Reset done	00:05:00	00:25:00	
11	WT	OT 5	limit switch control fuse blown out, found LS 2 cable got cut and got earthed	fuse replaced	02:50:00	03:00:00	