



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 13/05/2025

Area: OHP

Equipment	Job
CO-5,6,7,1A	CJB and LDB PPM done
JH-3 cO-14,15,16 take-up area	lighting contactor replaced
CO-9A,11A	Lighting PJB preparation done.
CO-67,70	Motor and panel PPM done
WOBR-1 ON CO-26	Control and power cable rejoin done.LT end limit striker and welded and machine operation testing done
BRC-2 on Repair Bay	22Kw CT motor shifted from Repair Bay to HVMCC-1 for overhauling
BRC-4	Shifted from CO-8A to CO-34