



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 26/07/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 32	Interlock cage stucked	made free	22:45:00	23:20:00	
2	OHP	CO 33M	OLR acted	reset done	23:50:00	23:55:00	
3	OHP	CO 33M	Yard stopping due to push button	cleaning and termination tightened done	00:10:00	00:30:00	
4	OHP	CO 26	OLR acted	reset done	01:00:00	01:10:00	
5	OHP	BRC on CO 32	CT not moving due to tire coupling problem	Tire coupling internal plates and screws changed	01:30:00	04:00:00	
6	OHP	CO 29	OLR acted	reset done	02:30:00	02:40:00	
7	OHP	CO 35	OLR acted	reset done ( 3 times)	23:11:00	05:00:00	
8	OHP	CO 30	OLR acted	reset done	03:00:00	03:10:00	
9	OHP	BRC on CO 31	BC direction to be reversed as per operation request	BC direction reversed and again kept back	23:30:00	02:50:00	
10	OHP	CO 14A	BRS not getting reset	reset PB terminal loose, tightened	05:15:00	05:30:00	
11	OHP	TT 3	Not moving	one phase loose in middle JB . Fixed properly	03:15:00	03:50:00	
12	OHP	TT 4	Not moving	LT MPCB tripped ( 2 times) bcz of material jamming	04:00:00	04:15:00	
13	CHP	CC 112, SCR 8	Slew , luffing not working	ACB ON feedback not coming. Bypassed in system .	00:30:00	01:00:00	
14	CHP	CC 34 , SCR2	LT not working due to pcrd overtension	released	01:55:00	02:15:00	
15	CHP	CC 104 , SCR 9	BC frequently stopping	checked, no electrical problem found , running okay.	02:00:00	02:20:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 26/07/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	CHP	CC 32 , SCR 5	BC not running	Coal stucked in ZSS cage . Made free	04:40:00	05:00:00	
17	CHP	CC 52	Tripped on overload	reset done	00:40:00	00:50:00	
18	CHP	CC 28	OLR acted	reset done	05:45:00	05:55:00	