



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 05/07/2025

Area: OHP

Equipment	Job
co-5 motor	vibration values were recorded along with technical services.
co-10,13,tt2	motor and panel ppm is done.
co-4a and its hoist	PPM at motor and panel side done.
wobr-25,26	bucket wheel motor status is checked.
brc-31	cabin fan is removed overhauling done and fixed back in brc-31 operator cabin
transfer car	PPM is done ; pcrd old motor is removed and spare motor is being arranged into position.
Daybins-1 compressor	compressor-1 olr is changed, and trail run taken.
losp-1 airblaster	auto operation is checked
sb-6 bunker area ; co44,49 gallery	lighting is improved.
brc-4 on co-34	rtd cable to AI card checked, insulated at few places and restored temperature interlock in circuit.