



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/11/2025

Shift: A

Incharge(s): K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|--|----------------------------|----------------------|----------------------|---------|
| 1 | OHP | VS-2 | OLR ACTED (2TIMES) | RESET DONE | 06:30:00 11:00:00 | 06:40:00 11:10:00 | |
| 2 | OHP | BRC ON CO-30 | B/C NOT RUNNING FOUND OLR ACTED | RESET DONE | 08:10:00 | 08:25:00 | |
| 3 | OHP | CO-67 | TRIPPED ON OLR | RESET DONE | 09:00:00 | 09:15:00 | |
| 4 | OHP | TT-4 | REPORTED NOT MOVE FOUND MPCB TRIP | RESET DONE | 12:10:00 | 12:25:00 | |
| 5 | OHP | CC-17 | STOPPING ON ZSS | SENSITIVE ADJUSTED THAN OK | 10:05:00 | 10:15:00 | |
| 6 | OHP | CO-29 | OLR ACTED | RESET DONE | 13:30:00 | 13:40:00 | |
| 7 | CHP | CC-37 | REPORTED NOT RUNNING | POWER RE-CYCLED THAN OK | 07:35:00 | 07:45:00 | |
| 8 | CHP | CC-201 | TRIPPED ON OLR | RESET DONE | 06:33:00 | 06:40:00 | |
| 9 | CHP | CC-125 | OLR ACTED | RESET DONE | 10:20:00 | 10:30:00 | |
| 10 | CHP | CC-105 | STOPPING ON ZSS CHECKED AND FOUND NO PROBLEM | CLEARANCE GIVEN THAN OK | 08:40:00 | 08:50:00 | |
| 11 | CHP | CC-17 | REPORTED STOPPING ON ZSS FOUND ZSS PROBE PROBLEM | ZSS PROBE REPLACED THAN OK | 07:45:00 | 08:15:00 | |
| 12 | CHP | CC-131 | OLR ACTED | RESET DONE | 07:30:00 | 07:35:00 | |
| 13 | CHP | CC-51 | MPD TRIP (10TIMES) FEEDING CONVEYOR STOP | RESET DONE | 07:40:00 | 13:30:00 | |
| 14 | CHP | CC-54 | OLR TRIP (2TIMES) | RESET DONE | 07:55:00 | 08:10:00 | |
| 15 | WT | CP-2 | REPORTED NOT MOVE FOUND COMMUNICATION PROBLEM | POWER RE-CYCLED IN LC-10A | 06:30:00 | 06:45:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/11/2025

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|---|-----------------------------------|----------|----------|---------|
| 16 | WT | OP-3 | REPORTED NOT MOVE FOUND DRIVE -1 TRIP COUPLING TIME | RESET DONE | 12:00:00 | 12:15:00 | |
| 17 | WT | OP-3 | NOT MOVE 5A-1 ROTAR CONTACTOR STUCK UP | FREE IT AND CLEANING DONE THAN OK | 12:25:00 | 12:45:00 | |