



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 01/09/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-20 TBS	SIGNAL MISSING (FOUR TIMES)	NO PROBLEM FOUND	23:35:00	00:30:00	
2	OHP	CO-25	OLR ACTED	RESET DONE	22:55:00	23:00:00	
3	OHP	TT4	FLAP GATE NOT WORKING	NO ELECTRICAL PROBLEM	23:00:00	23:20:00	
4	OHP	TBS ON CO-19	LBC ZSS PROB CHANGED	AND KEPT IN CKT	22:40:00	23:20:00	
5	OHP	BRC ON CO -31	LT NOT WORKING OVER TENSION	RELEASED	02:50:00 23:30:00	03:10:00 23:45:00	
6	OHP	CO-25	ZSS CAGE STUCK	MADE FREE	02:30:00	02:45:00	
7	OHP	CO-5A TBS	BC STOPING ON ZSS	CAGE STUCK MADE FREE	02:30:00	02:45:00	
8	OHP	CO -87	OLR ACTED	RESET DONE	03:30:00 03:55:00 04:50:00 05:15:00	03:40:00 04:00:00 05:00:00 05:20:00	
9	OHP	CO-19 TBS	STONE STUCK IN ZSS CAGE	MADE FREE	01:30:00	01:50:00	
10	OHP	CO-31 BRC	CT LT NOT RUNNING	DRIVE TRIPPED .. RESET ... PCRD TRIP.. RESET AND GUIDE PROBLEM	05:30:00	06:00:00	
11	OHP	CO-24 TBS	LT NOT WORKING	BOOM IS NOT AT RECLAMING HEIGHT ... LUFF UPM DONE	00:15:00	00:35:00	
12	OHP	BRC ON CO-34	PUMP NOT STARTING	OIL LEVEL LOW .. INFORMED OPR	01:00:00	01:15:00	
13	CHP	CC-35 S-2	LT NOT WORKING	TRACK JAMMING ... DRIVE TRIP .. RESET ..AND OT RELEASED INFORMED FOR CLEANING	00:00:00 01:50:00	00:15:00 02:10:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/09/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC-39 SCR-7	BC NOT WORKING	DISCHARGE CHUT JAMMING INFORMED FOR CLEANING	01:00:00 04:00:00	01:30:00 04:30:00	
15	CHP	CC-112 SCR-8	LUFF NOT WORKING ... OIL LEVEL LOW	INFORMED MECH	02:10:00	02:40:00	
16	CHP	CC-39 SCR-7	SLEW NOT WORKING ... OIL TEMP HIGH	COOLER MADE ON AND RESET AFTER TEMP COMING DOWN	03:00:00	03:45:00	
17	CHP	CC-51A	TRIPPED ON OL	RESET DONE	00:10:00 00:25:00	00:15:00 00:30:00	
18	WT	CP-3	TRIPPED TWICE IN COLUMN NO 48 , 49	CHECKED AND MADE ON	23:30:00	00:00:00	
19	IOSA	L and T WOBR	`LT NOT WORKING .. M3 BREAK MPCB TRIP	RESET DONE	01:10:00	01:20:00	
20	IOSA	L and T WOBR	HYDRAULIC PUMP NOT STARTING	OIL LEVEL LOW .. INFORMED MECH	05:40:00	05:50:00	