



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 03/12/2025

Area: WT

Equipment	Job
MIS	Spare Break panels made ready in both LC 1 and LC 9
OT 3	Break panel rectified ,2nos Diodes replaced and C2 cantactor 40 A replaced
LC 2B	Space Heater Supply checked and found available in both T1 and T2
LC 2A	Supply provided for space heater with MCB control for T2
CP 1 and 4	After rake, maintenance done
OP 4 and 6	After rake, maintenance done