



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 17/12/2025

Area: CHP

Equipment	Job
LC 15 to LC 16	Profibus cable laid temporarily and restored communication up to CM 16. Permanent cable laying under progress
CC 39,104,105,107,108,219,222,223,SCR 9,10,S1	Motors greasing done
CC 107,222,223	PPM was done
S1 and SCR 6	Yard machines interchanged