



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/01/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO-20	REPORTED LT NOT TAKING PLACE FOUND PCRD O/T ACTED	RELEASED AND PCRD GUIDE ADJUSTED	06:40:00	07:00:00	
2	CHP	CC-28	TRIPPED ON OLR (2TIMES)	RESET DONE	10:50:00 12:20:00	11:00:00 12:30:00	
3	CHP	CC-51	OLR ACTED	RESET DONE	08:00:00	08:10:00	
4	CHP	CC-51	MPD TRIP (6TIMES) FEEDING CONVEYOR STOP	RESET DONE	07:00:00	13:30:00	
5	CHP	CC-31	MPD TRIP (E108)	RESET DONE	07:30:00	07:35:00	
6	CHP	CC-112 SCR-8	REPORTED B/W NOT RUNNING CHECKED AND FOUND NO PROBLEM	POWER AND CONTROL RE-CYCLED THAN OK	08:15:00	08:45:00	
7	CHP	CC-216	OLR ACTED	RESET DONE	08:40:00	08:50:00	