



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 10/10/2025

Area: CHP

| Equipment | Job |
|---------------------|---|
| STK-3 | Lower E-House roof sheet welding job is under progress |
| STK-3 | Slew movement, motors given power from drive without coupling and tested. One motor mounted on base coupling fixed and tested the movement with drive. Found ok |
| CC-43,46,49,126,125 | Running inspection done |
| CC-40,42,46 | ppm done |