



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 20/10/2025

Area: WT

Equipment	Job
cp-3	panel and motor side ppm done
op-6	Trolley line checking done found top section bus bar misaligned at col no:31 rectified it then ok.