



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 26/05/2025

Area: WT

Equipment	Job
OP 10	D4 motor checked found winding OPEN,kept in bypass ( power kept OFF in drive panel)
OP 10	D4, motor bed bolts found loose and misalignment ,realignment bolts fixing done
OP 9	Went to Non-Power zone,Brought to Parking zone,Forward limit 1 kept in bypass