



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 03/06/2025

Area: OHP

| Equipment | Job |
|--------------------|--|
| CO-5,6,7,1A,JH-2 | Lighting panel maintenance done |
| JH-3 to JH-4 | Lighting done and rectification done |
| Day bin Compressor | Air Blaster phase fault rectification done |
| CO-49 | Chute sensor earthing provided |
| CO-14A,14B,49 | Hoist PPM done |
| WOBR ON CO-26 | Brake panel shifting done and positioning and welding done |
| TBS-7 on CO-19 | PPM done |
| CO-5A | PPM done |
| TBS-4 ON CO-5A | PPM done |