



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 13/09/2025

Area: WT

Equipment	Job
co-5,6 and 7	co-7 and co-1a between area 200w led replaced
cc-7,8 and 9	Tail end area 120 and 200w led replaced
op-5	At first c-type box from tippler B-Phase lugs melted at trolley line replaced with new lugs.
op-5	At col no:97 crossarm fallen in between busbars removed it