



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/05/2025

Shift: C

Incharge(s): Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 11 carriage drive	MPCB tripped	made on	00:50:00	01:00:00	
2	OHP	RSCO 6A carriage drive	OLR acted	reset done	01:20:00	01:30:00	
3	OHP	BRC on CO 30	PCRD overtension and guide problem	Informed to mechanical	00:45:00	01:00:00	
4	OHP	BRC on CO 33M	Pump not starting , oil level low	Informed to mechanical	02:30:00	02:50:00	
5	OHP	BRC on CO 30	BC not running due to OLR acted (2 times)	reset done	03:00:00 04:40:00	03:20:00 04:50:00	material jamming , informed to operation
6	OHP	TT 3 on CO 21	Position indication problem due to male plug damaged and 2 glass fuses blown in JB	Plug replaced and fuses replaced . Then indication ok	04:30:00	05:00:00	
7	CHP	CC 27A	BRS acted	reset done	23:50:00	23:55:00	
8	CHP	CC 33 , SCR 4	Luffing problem	Control and power reset done	22:45:00	23:00:00	
9	CHP	CC 202	Unhealthy	Checked and found drive end chute jammed, informed to operation	02:30:00	02:45:00	
10	CHP	CC 203	Not running	Checked and found jamming and fluid coupling oil leakage	02:50:00	03:10:00	Informed to mechanical



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/05/2025

Incharge(s): Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
11	CHP	CC 34 , S-1	Cable in overlapped condition	gearbox problem , cable drum arrested . Also informed to mechanical and information	02:40:00	03:40:00	
12	CHP	CC 32 , SCR 5	LT not working	Drive tripped , reset done	05:20:00	05:30:00	
13	CHP	CC 131	Tripped in overload (5 times)	reset done	23:15:00	01:45:00	
14	CHP	CC 54	Tripped in overload (6 times)	reset done	00:50:00	04:20:00	
15	CHP	CC 35 , SCR 2	Luffing temperature showing High due to jammed radiator	Bypassed in IO rack after mechanical request	22:00:00	22:05:00	
16	CHP	CC 132	BRS bypass required as per operation request	Bypass done	00:40:00	00:50:00	
17	WT	OT 5	Drive 1 tripped in overload	reset done	23:20:00	23:25:00	
18	IOSA	OC 25A to OC 37A	Not healthy due to communication error	PLC power recycled in LC 9, Aug OM 1 and 4	03:45:00	04:00:00	