



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

#### ELECTRICAL SHIFT REPORT

Date: 25/08/2025

Incharge(s): Lal Singh

Shift: C

| Sl No | Area | Equipment        | Problem                                     | Action                         | From     | To       | Remarks           |
|-------|------|------------------|---|--------------------------------|----------|----------|-------------------|
| 1     | OHP  | CO21             | BRS bypassed as per operational requirement | bypassed                       | 01:10:00 | 01:20:00 |                   |
| 2     | OHP  | TIS 5 on CO25    | Bypassed as per operational request         | bypaased                       | 02:00:00 | 02:20:00 |                   |
| 3     | OHP  | VF8a             | Chute vibrator MPCB trip                    | Reset and made on              | 23:40:00 | 23:45:00 |                   |
| 4     | CHP  | CC-34 SCR-2      | LUFF OIL TEMPERATURE                        | KEPT IN CKT                    | 22:30:00 | 22:40:00 |                   |
| 5     | CHP  | SCR-10 ON CC-105 | BC MPD TRIPPED ON EF                        | RESET DONE AND TESTED          | 03:30:00 | 03:45:00 |                   |
| 6     | CHP  | CC-40            | BRS UNIT NO POWER.... FUSE blown            | REPLACED AND TESTED            | 02:50:00 | 03:10:00 |                   |
| 7     | CHP  | CC-37 S-1        | SIGNAL MISSING FREQUENTLY                   | SCR-2 USED AS repeater FOR S-1 | 22:30:00 | 22:50:00 |                   |
| 8     | CHP  | CC-113           | STOPPED ON ZSS                              | PULLY SLIPPING                 | 05:15:00 | 05:25:00 |                   |
| 9     | CHP  | CC28             | chute sensor malfunctioning due to rain     | Bypassed                       | 04:45:00 | 04:44:00 | may check further |
| 10    | WT   | OP-2             | BOTTOM PAD C AND U CLAMP PROBLEM            | CHANGED                        | 22:00:00 | 23:00:00 |                   |
| 11    | WT   | CO3 belt         | olr acted                                   | reset done                     | 04:45:00 | 04:50:00 |                   |