



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 14/08/2025

Area: WT

Equipment	Job
OT 5 series	Panel and Motor side ppm done
OP 3	D1 Over Load Relay checked ,found OK bypass removed and D4 kept in circuit after Mech. clearance
CP 4	Trolley line checking done ,Middle and Bottom C - Clamps replaced,Bus bar adjusted @ 77 and 68
CP 3	After rake maintenance done, one lug replaced in D4
OP 1,4 and 8	After rake maintenance done