



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 27/11/2025

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 10 A	OLR ACTED	RESET	17:15:00 19:50:00	17:20:00 20:00:00	
2	CHP	CC 51	OLR ACTED	RESET	19:15:00	19:20:00	
3	CHP	CC 22 CARRIAGE DRIVE	OLD JOINT OPENED	RECONNECTED	17:00:00	17:20:00	
4	CHP	CC 132	OLR ACTED	RESET	21:45:00	21:50:00	
5	CHP	SCR 3 ON CC 35	OIL LEVEL LOW	INFORMED TO OPRN	21:20:00	21:35:00	
6	CHP	CC 213 ZSS	TAIL END AND DRIVE END FULL JAMMING	INFORMED TO OPRN	16:45:00	17:00:00	
7	CHP	SCR 4 ON CC 31 LT	O/T ACTED CABLE FELL DOWN	RELEASED AND WINDING DONE	18:40:00	19:10:00	
8	CHP	SCR 10 ON CC 105 LT	PCRD GUIDE PROBLEM	INFORMED TO MECH FOR ADJUSTMENT	21:45:00	22:00:00	
9	IOSA	BRC ON OC 15A	ZSS INTERLOCK CAGE STUCK	REMOVED THEN OK	19:40:00	19:50:00	