



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 15/02/2026

Shift: A

Incharge(s): Amit Roy

| Sl No | Area | Equipment     | Problem                             | Action   | From     | To       | Remarks                          |
|-------|------|---------------|-------------------------------------|--|----------|----------|----------------------------------|
| 1     | OHP  | CO-1A         | Reported ZSS acting                 | Module problem.Module replaced and tested okay                                 | 09:00:00 | 09:30:00 |                                  |
| 2     | OHP  | WOBR on CO-29 | Reported B/W not rotating           | OLR acted.Reset done   | 09:45:00 | 09:55:00 |                                  |
| 3     | OHP  | CO-26         | Reported tripped                    | OLR acted.Reset done(2 times)  | 09:45:00 | 10:55:00 |                                  |
| 4     | OHP  | BRC on Co-33M | Reported LT not taking place        | PCRD tension acted.Released and tested okay                                    | 11:45:00 | 12:00:00 |                                  |
| 5     | CHP  | CC-104 SCR-7  | B/C stopping frequently             | ZSS cage stuck with material.Made free and tested okay                         | 10:35:00 | 10:50:00 |                                  |
| 6     | CHP  | CC-105 SCR-10 | Lt not taking place                 | PCRD cable found totally unwinded laying on ground.Laying done and tested okay | 07:40:00 | 08:00:00 |                                  |
| 7     | CHP  | Cc-213 SCR-9  | Reported no operations taking place | ACB in off condition.Made on and tested okay                                   | 10:40:00 | 10:55:00 | Operator pressed E-stop at cabin |
| 8     | CHP  | Cc-216        | Reported tripped                    | OLR acted.Reset done   | 10:40:00 | 10:50:00 |                                  |
| 9     | CHP  | Cc -108       | Reported tripped                    | MPD tripped.Reset done and tested okay   | 11:55:00 | 12:00:00 |                                  |