



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 04/07/2025

Area: IOSA

Equipment	Job
MANUAL YARD	LIGHTING DEFECTS RECTIFIED AND REPLACED DEFECTIVE LIGHT FITTING.
TBS	PCRD CHAIN TENSIONING UNIT BROKEN . TRIAL RUN TAKEN AFTER RECTIFICATION
OC-37A	PPM DONE ON MOTOR AND FIELD DEVICES. SPARE MOTOR MAINTENANCE DONE.