



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 21/06/2025

Area: OHP

Equipment	Job
co-6a	motor and panel ppm is done
brc-4	hooter working status is checked.
tbs-19	right boom luff brake panel is covered.
lt motor 5.5KW	bearing replaced and overhauling is done.
brc-2	pcrd layering is done properly.
wbr on co-26,29,25	bucket wheel motor inspection is done.
All yard machines	cable inspection is done and space heaters at couplers is done.
brc-2	shifted form co-32 to co-30
co-38b cjd	rectified and kept in circuit.
co-5 t/e pullchord	2 switched replaced and taken into circuit.
co-3a,2a brs	electronic brs delay with a delay of 3seconds is wired and kept in circuit.,
co-43a	panel side control wiring and cjb modification is done and io bits rearranged.