



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/06/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	TRIPPED ON OLR	RESET DONE	15:15:00 19:15:00	15:25:00 19:20:00	
2	OHP	CO-20 TBS	LT NOT WORKING	PCRD TENSION ACTED RELEASED	16:00:00	16:15:00	
3	OHP	CO-6A WOBR	PUMP NOT RUNNING	OIL TEMP IS HIGH STARTED AFTER TEMP. COMING DOWN ... CHECKED OIL COOLER WORKING	19:00:00	19:30:00	
4	OHP	CO-6	PULL CORD ACTED	BYPASSED AND CHECKED NO SWITCH IS IN ACTED CONDITION	16:45:00	16:55:00	TO BE CHECKED
5	CHP	CC-23	C/D FESTOON CABLE DAMAGED	JOINT DONE	17:10:00	17:45:00	
6	CHP	CC-34 SCR-2	LT NOT WORKING	PCRD OVER TENSION ACTED RELEASED	18:30:00	18:45:00	
7	CHP	CC-36 SCR -1	SLEW NOT WORKING	30 DEGREE LIMIT ACTED	15:50:00	16:10:00	
8	CHP	CC-104 SCR-9	LUFF PUMP STOPPING	SUCTION PUMP LS-2 RETURN BIT NOT COMING ... BYPASSED IN IO RACK	16:20:00	17:30:00	
9	CHP	CC-33 SCR-4	BC STOPPING ON ZSS	COAL STUCK IN ZSS CAGE ... REMOVED	18:50:00	19:05:00	
10	CHP	CC-131	TRIPPED ON OLR	RESET DONE	16:00:00 19:30:00	16:05:00 19:35:00	