



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/10/2025

Shift: C

Incharge(s): K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-------------|--|------------------------------------|----------------------------------|----------------------------------|---------|
| 1 | OHP | CO-29 | OLR ACTED | RESET DONE | 23:00:00 | 23:10:00 | |
| 2 | OHP | CO-26 | OLR ACTED (3TIMES) | RESET DONE | 01:40:00 03:00:00 03:40:00 | 01:50:00 03:10:00 03:50:00 | |
| 3 | OHP | CO-84 | OLR ACTED (3TIMES) | RESET DONE | 02:00:00 03:20:00 03:30:00 | 02:10:00 03:30:00 03:40:00 | |
| 4 | OHP | CR-3 | OIL FLOW LEVEL LOW | FAULT RESET DONE THAN OK | 05:30:00 | 05:40:00 | |
| 5 | CHP | CC-51 | MPD TRIP (6TIMES)FEEDING CONVEYOR | RESET DONE | 03:30:00 | 05:00:00 | |
| 6 | CHP | CC-54 | OLR ACTED | RESET DONE | 01:00:00 | 01:10:00 | |
| 7 | CHP | CC-32 R-1 | B/C STOPPING FREQUENTLY FOUND ZSS PROBE CABLE GOT CUT | ZSS PROBE CABLE JOINT DONE THAN OK | 00:05:00 | 00:25:00 | |
| 8 | CHP | CC-33 SCR-5 | LT NOT TAKING PLACE CHECKED AND FOUND DRIVE FAULT P10 TRIP | RESET DONE (2TIMES) | 00:30:00 02:30:00 | 01:10:00 02:50:00 | |
| 9 | CHP | CC-32 R-1 | LUFFING DOWN NOT WORKING CHECKE3D NO ELECTRICAL PROBLEM DUE TO JAMMING | CLEAR MATERIAL THAN OK | 01:25:00 | 01:40:00 | |
| 10 | CHP | CC-125 | D/E SIDE CHUTE SENSOR ACTED | SENSOR CLEANED THAN OK | 01:05:00 | 01:20:00 | |
| 11 | CHP | CC-33 SCR-2 | LT NOT TAKING PLACE MPCB-4 TRIPPED | RESET DONE THAN OK | 02:50:00 | 03:10:00 | |
| 12 | CHP | CC-40 SCR-3 | B/C OLR ACTED | RESET DONE | 04:10:00 | 04:20:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/10/2025

Incharge(s): K SANKARA RAO

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|--|------------------------|----------|----------|---------|
| 13 | CHP | CC-38 SCR-6 | SLEW NOT WORKING OIL LEVEL LOW | INFORMED TO MECHANICAL | 03:45:00 | 04:00:00 | |
| 14 | CHP | CC-33 SCR-5 | B/W OLR ACTED | RESET DONE | 04:45:00 | 05:10:00 | |
| 15 | CHP | CC-38 SCR-6 | SLEW NOT WORKING RIGHT LIMIT ACTED | LIMIT RELEASE THAN OK | 05:10:00 | 05:20:00 | |
| 16 | WT | OT-1 | REPORTED NOT MOVE FOUND DRIVE-1PGF1, FAULT TRIP | RESET DONE | 23:30:00 | 23:40:00 | |