



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 21/08/2025

Shift: A

Incharge(s): Amit Roy

| Sl No | Area | Equipment     | Problem                        | Action   | From                 | To                   | Remarks               |
|-------|------|---------------|--------------------------------|--|----------------------|----------------------|-----------------------|
| 1     | OHP  | CO-29         | Reported tripped               | OLR acted.reset done   | 10:15:00             | 10:20:00             |                       |
| 2     | OHP  | CO-12(C/D)    | Reported tripped               | OLR acted.Reset done   | 10:20:00             | 10:25:00             |                       |
| 3     | OHP  | RSCO-10A(C/D) | Reported not moving            | Tripped on olr.Reset done  | 12:10:00<br>12:25:00 | 12:15:00<br>12:30:00 |                       |
| 4     | OHP  | WOBR on CO-26 | Reported slew not taking place | Drive tripped on OLR.Reset done  | 13:40:00             | 13:50:00             |                       |
| 5     | CHP  | CC-51         | Reported tripped               | OLR acted(5times)  | 11:00:00             | 12:00:00             |                       |
| 6     | CHP  | CC-34 SCR-2   | Reported LT not taking place   | PCRD OT acted.Released and tested okay   | 08:18:00             | 08:30:00             |                       |
| 7     | CHP  | CC-45         | Reported ZSS problem.          | bypassed due to demand.  | 10:38:00             | 10:50:00             | Probe to be changed   |
| 8     | CHP  | CC-48         | Reported D/E CJD not working   | Cable damaged. Rejoint done and tested okay  | 11:15:00             | 11:25:00             |                       |
| 9     | CHP  | CC-201        | Reported tripped               | OLR acted.Reset done   | 11:23:00             | 11:30:00             |                       |
| 10    | CHP  | CC-104 SCR-9  | B/W not rotating               | Operator cabin reset done and tested okay  | 12:30:00             | 12:50:00             |                       |
| 11    | WT   | OP-10         | Reported not moving            | C clamp fallen down at column no.64.C clamp kept in position and tested okay.Breaker tripped. made on  | 10:30:00             | 10:50:00             | C clamp to be changed |
| 12    | WT   | OP-1          | Reported not moving            | Drive-4 tripped.Motor lug got cut and base bolts and brushes also damaged.Relugging done,base bolts(2nos.)changed and brushes changed by general shift | 11:40:00             | 13:50:00             |                       |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 21/08/2025

Incharge(s): Amit Roy

Shift: A

| Sl No | Area | Equipment                    | Problem              | Action  | From     | To       | Remarks |
|-------|------|------------------------------|----------------------|---|----------|----------|---------|
| 13    | WT   | OT-3,4<br>hopper<br>lighting | Reported no lighting | Fuse and base burnt. Replaced with new set and<br>lighting restored | 11:00:00 | 11:30:00 |         |