



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 08/05/2025

Area: WT

| Equipment | Job |
|-----------|--|
| OP 9 | |
| | lighting circuit problem,rectified |
| OP 5 | motors checked found D4 slipping problem,unit removed and rotor cable shorted and drive bypassed |
| | after rake maintenance done |

CO3 &4 stair case

OP 1,2,3,4,6,CP1 &3