



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 24/01/2026

Area: CHP

Equipment	Job
Lighting Towers	Jungle cutting done for lighting rectification
LC 18,CM 17,18	IO rack Prophi bus looping cables replaced with new loops
SCR 8,9,10	3nos 120W and 2 nos 200W LED fixtures provided
LC 17	Transformer rooms cleaning done
All yard machines	PCRD inspection was done and rectified the defects
CC 114,115	Panel side PPM was done