



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 09/09/2025

Shift: B

Incharge(s): Lal Singh

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-85	TRIPPED ON OLR	RESET DONE	15:00:00	15:06:00	
2	OHP	BRC ON CO-28	BC OLR ACTED	RESET DONE	16:40:00	17:00:00	
3	OHP	CO-20	LBC TRIPPED DUE TO JAMMING	RESET .. INFORMED FOR CLEANING	18:45:00	19:00:00	
4	OHP	BRC ON CO-34	CT NOT MOVING . CABIN SIDE LIMIT STUCK	RELEASED	19:55:00	20:10:00	
5	OHP	WBR ON CO-26	SLEW DRIVE TRIPPED	RESET DONE	20:35:00	20:55:00	
6	OHP	CO-61	PULL CORD ACTED ... BELT FALLEN BECAUSE OF OFFCENTRING	INFORMED OPR	21:00:00	21:15:00	
7	OHP	OP-3	D1 CONTACTOR PROBLEM	RECTIFIED	14:00:00	14:30:00	
8	CHP	CC-28	TRIPPED ON OLR	RESET DONE	15:50:00	16:00:00	
9	CHP	CC-29	TRIPPED ON OLR	RESET DONE	18:20:00 18:50:00 20:00:00	18:25:00 18:55:00 20:05:00	
10	CHP	CC-51	MPD TRIPPED (7 TIMES )	RESET DONE	18:20:00	22:00:00	
11	CHP	RG-2	BEARING TEMP HIGH	INFORMED MECH AND RESET DONE	16:40:00	16:50:00	
12	CHP	CC-51 TIS	TIS CHAIN PROBLEM	FEEDBACK BYPASSED	14:50:00	15:00:00	
13	CHP	CC-40 SCR-3	PCRD OT ACTED	RELEASED	16:30:00	16:40:00	
14	CHP	CC-38 SCR-6	SIGNAL MISSING	INTERLOCK ZSS KEPT IN LINE	20:20:00	20:40:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 09/09/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	WT	OT-5	NOT RUNNING ... BREAK RECTIFIER PROBLEM	CHANGED	19:30:00	20:50:00	