



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 29/08/2025

Area: WT

Equipment	Job
OP 1	D4 motor removed from bed due to motor coupling loose
OP 2	Panel and motor side ppm done
OP 1 and 5	After rake maintenance done