



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

#### ELECTRICAL SHIFT REPORT

Date: 02/08/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 31 BRC	LT not working, M6 motor mpcb trips	made it on	00:50:00	01:10:00	
2	OHP	co 33 M brc	b/w 1 not rotating, stone stucked in b/w	informed mech	01:45:00	01:55:00	
3	OHP	CO 12(c)	mpcb tripped due to overload	made it on	05:50:00	06:00:00	
4	CHP	CC 32 SCR 5	Lt not taking place, m2 mpcb trip	made it on	22:55:00	23:05:00	
5	CHP	CC 125	olr acted	reset	01:00:00	01:05:00	3 times
6	CHP	CC 34 scr 2	LT not taking place, OT acted	OT released	02:20:00	02:30:00	
7	CHP	CC 39 SCR 6	LT not taking place, drive trips in overload	reset	03:55:00	04:10:00	
8	CHP	CC51	Motor mpd tripped on over load	Reset done	22:50:00	22:55:00	
9	CHP	CC54	Overload tripped in 6 times	reset done	23:00:00	23:07:00	11.10pm to 11.15pm: 11.26 to 11.30pm: 11.35 pm to 11.40 pm: 01.35am to 01.40am: 01.50 am to 01.55am
10	CHP	CC26	Mechanical BRS acted handle problem	handle Adjusted	04:30:00	04:40:00	
11	WT	OP2	pusher no movement, d5 OLR acted	reset	02:00:00	02:20:00	brake winding
12	WT	op3	pusher no movement, d5 OLR acted	reset	05:20:00	05:30:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 02/08/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	IOSA	L and T WOB	BW and slew not working found pump not able to on and pump ball valve LS 6 closed condition	Reset done	23:50:00	00:10:00	