



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/02/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLr acted	reset	00:10:00	00:19:00	4 times
2	OHP	TBS on CO 20	l/luff and BC not running,olr acted	reset	22:30:00	22:45:00	
3	OHP	CO 1A	ZSS problem ,not electrical problem,belt stucked thats why zss acted	checked motor side zss all ok,run in local and clear jamming ,told operation	01:45:00	02:00:00	mech problem
4	CHP	cc 203	olr acted	reset	22:35:00	22:45:00	
5	CHP	CC 105 scr 10	m/c physically ohp side but shown gvm side,limit switch stucked	slew done than ok	22:50:00	23:00:00	
6	CHP	cc 104 scr 7	LT not working PCRD cable tension	OT released	04:05:00	04:15:00	
7	CHP	cc 104 scr 7	LT not working,wrong complaint	operator problem	05:15:00	05:20:00	
8	CHP	CC 51	MPD acted	reset	05:00:00	05:05:00	6 times
9	CHP	C C 117	OLR acted	reset	22:00:00	22:10:00	
10	CHP	CC 31 SCR4	luff not working,oil temp high,glass fuse blown	fuse replaced	23:35:00	23:59:00	