



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 07/09/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO-28	B/C OLR ACTED(2TIMES)	RESET DONE	15:20:00 16:05:00	15:40:00 16:15:00	
2	OHP	CO-67	OLR ACTED	RESET DONE	16:00:00	16:10:00	
3	OHP	WOBR ON CO-26	SLEW NOT WORKING CHECKED DRIVE TRIP	RESET DONE	17:40:00	18:00:00	
4	OHP	CO-25	OLR ACTED (2TIMES)	RESET DONE	18:05:00 18:35:00	18:20:00 18:40:00	
5	OHP	BRC ON CO-34	B/C OLR ACTED (3TIMES)	RESET DONE	18:40:00	19:40:00	MECHANICAL GEAR BOX SIDE PROBLEM INFORMED TO MECH
6	OHP	TBS ON CO-5A	LT NOT TAKING PLACE CHECKED M-4 OLR ACTED	RESET DONE	20:45:00	21:00:00	DUE TO TRACK JAMMING INFORM TO OPERATION
7	OHP	CO-84	OLR ACTED	RESET DONE	21:25:00	21:30:00	
8	CHP	CC-26A	OLR ACTED	RESET DONE	15:25:00	15:35:00	
9	CHP	CC-105 SCR-10	ALL DRIVES ARE NOT RUNNING ACB TRIP	ACB MADE ON THAN OK	14:30:00	14:50:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 07/09/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
10	CHP	CC-40 SCR-3	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED THAN OK	16:00:00	16:10:00	
11	CHP	CC-46	REPORTED C/S NOT WORKING CHECKED NO PROBLEM	WRONG COMPLAINT	18:00:00	18:05:00	
12	CHP	CC-112 SCR-8	LUFFING NOT WORKING CHECKED AND FOUND SHOW OIL LOW LEVEL BUT OIL IS FULL	BY PASSED THAN OK	20:10:00	20:20:00	
13	CHP	CC-51	OLR ACTED (5TIMES) DUE TO FEEDING CONVEYOR OVER LOAD STOP	RESET DONE	17:15:00	20:15:00	
14	CHP	CC-54	OLR ACTED	RESET DONE	16:35:00	16:40:00	