



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 29/08/2025

Area: CHP

| Equipment | Job  |
|-----------|--|
| SCR 6,7   | Slew and Luff instrumentation switches cleaned and covered         |
| SCR 5     | LUFF oil level ckt problem rectified and kept in ckt               |
| RG EOT    | PPM was done   |
| SCR 1     | Boom position kept in ckt  |
| JH 210    | Lighting improved by providing 5 nos 30W LED lamps                 |
| SCR 10    | Bucket wheel main pump ckt problem rectified, Boom ZSS kept in ckt |
| SCR 2     | Stacking angle increased as per operation requirement              |
| CC 37     | TUL chute sensor modification done                                 |