



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 15/12/2025

Area: CHP

Equipment	Job
Cm 9 to JH3	4*70 AL cable laid for welding machine supply
Tis on CC 130	NGEF Isolator supply cable problem rectified
CC 58 T/T	Cable joint done
CC 108	BRS kept in circuit
SCR6	Luff Up limit kept in circuit
CC 31, 32, 36 SCR 4, SCR5 ,S2,S3	Greasing done
CC 8, Tis on CC 8, CC 108, 213, 219,	PPM done
SCR 4	Ht cable old joint wrapper provided by DNW
IC 1	Bus bar maintenance done