



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 02/07/2025

Area: WT

| Equipment  | Job   |
|------------|---|
| OP 10      | Creepers along trolley line removed bottom side from col no 15 to 3 |
| OC 1A      | Area lighting problem rectified ,200W and 35W LEDs replaced         |
| OP 1 and 4 | after rake maintenance done   |