



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 16/07/2025

Area: OHP

Equipment	Job
BRC-5 on CO-33M	PPM done
wobr-1	io rack panel sifted into mcc and welded in position.
co-2a	motor and panel side ppm is done
co-111,112,113	estops replaced
daybins-1	illumination improved along each conveyor levels.
vf-21 and vf-23	Feed rate increased by 10% for each