



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/02/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 48	OLR ACTED	RESET	03:45:00	03:55:00	
2	OHP	CO 14	OLR ACTED	RESET	04:00:00	04:05:00	
3	OHP	CC 28	OLR ACTED	RESET	04:15:00	04:20:00	
4	OHP	CO 25	OLR ACTED	RESET	02:30:00 03:30:00 22:50:00	02:40:00 03:40:00 23:00:00	
5	OHP	BRC ON C0 31 LT	SELECTOR SWITCH IS IN LOCAL	CHANGED TO REMOTE	02:50:00	03:00:00	
6	CHP	SCR 8 ON CC 112	B/C OLR ACTED	RESET	01:10:00	01:25:00	
7	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	23:00:00	06:00:00	16 TIMES
8	CHP	SCR 4 ON CC 31	COMMUNICATION PROBLEM	LT DONE THEN OK	00:30:00	00:45:00	
9	IOSA	IOSA	COMMUNICATION PROBLEM	POWER RECYCLED IN 1-142LC-1 BUILDING REMOTE I/O 7 THEN OK	05:10:00	05:25:00	