



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 11/12/2025

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 111	OLR ACTED	RESET	17:30:00	17:40:00	
2	OHP	RCO 1A	ZSS ACTING DUE TO SOME PULLEY TARGETS MISSING	BYPASSED	21:20:00	21:30:00	TARGETS NEED TO BE WELDED
3	OHP	CO 32	OLR ACTED	RESET	18:40:00	18:50:00	
4	OHP	CO 29	OLR ACTED	RESET	15:25:00 20:40:00	15:30:00 20:50:00	
5	OHP	TBS ON CO 21 LT	M1 , M2 TRIPPED	RESET	21:35:00	21:45:00	
6	OHP	NEW LC3	INCOMER 2 TRIPPED (Lt side)	MADE IT ON	18:50:00	19:00:00	
7	OHP	TBS ON CO 5A	B/C SIGNAL MISSING	ALL CONNECTIONS TIGHTENED THEN OK	16:45:00	17:05:00	
8	CHP	CC 54	MCCB TRIP	RESET	17:05:00	17:15:00	
9	CHP	CC 131	OLR ACTED	RESET	19:15:00	19:20:00	
10	CHP	RG2 F/G	OLR ACTED	RESET	20:55:00	21:00:00	
11	CHP	SCR 10 ON CC 105 SLEW	CHARGE PRESSURE ACTING	BYPASSED AS PER MECH REQUEST	16:30:00	16:45:00	
12	CHP	SCR 9 ON CC 104 SLEW	OLR ACTED	RESET	18:20:00	18:30:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 11/12/2025

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	SCR 6 ON CC 38 LT	M2 TRIP DUE TO TRACK JAMMING	RESET AND INFORMED TO OPRN	18:50:00 19:15:00	19:00:00 19:20:00	
14	CHP	CC 222	DRIVE TRIPPED	RESET	18:40:00	18:50:00	
15	CHP	CC 125	OLR ACTED	RESET	19:00:00 20:25:00	19:05:00 20:30:00	
16	WT	AF 6	DRIVE TRIPPED	RESET	19:45:00	19:50:00	