



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 12/12/2025

Area: WT

Equipment	Job
CM 7	Data cable panel blowing done and 2 nos tubes replaced
CO 3 and 4 area	Lighting problem rectified, 1 no 200 W LED and 15 mtrs cable replaced
CO 4(Belt)	NGEF module ,sliding contact replaced
OP 3,4,5,7 and 9	After rake maintenance done