



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/06/2025

Area: WT

Equipment	Job
MIS	U4,U15 and coal dead end lighting job done ,3 nos LED, 200w installed,cable laid from OP 7 to Op 8
CP 3	All drives checked in de clutch position ,cascading timer kept in circuit,D2 motor re alignment done
OP 5	Middle C and U clamps replaced
OP 5	Trolley line inspection done,Col no 11-12 area cross arm angles cutting done
OP 1,6 and CP 2	after rake maintenance done