



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/08/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 35	olr acted	reset	10:20:00	10:30:00	
2	OHP	co 29	olr acted	reset	10:10:00	10:15:00	2 times
3	OHP	BRC on co 30	b/c not healthy, emergency PB acted near operator cabin	emergency released but healthy not coming, emergency PB contact open and close	07:55:00	08:25:00	operator not available in machine
4	OHP	RSCO 6a	chute vibrator not working, MPCB is in off	mpcb made it on	07:15:00	07:20:00	
5	OHP	WOBR CO 29	b/c not running ,zss cage check nut loosed	ZSS check nut tightened	12:50:00	13:10:00	
6	OHP	CO 11(c)	MPCB tripped	made it on	13:20:00	13:25:00	
7	CHP	CC 105 SCR 7	TUL cjs not healthy,	cleaning done CJS than healthy	07:00:00	07:15:00	
8	CHP	CC 33 SCR4	b/c not running, CJS acted	reset it done	08:40:00	08:50:00	
9	CHP	CC 105 SCR7	slew not working, oil level low alarm in spider	informed mech and operation	10:10:00	10:20:00	
10	CHP	CC 51	not healthy, pull chord and emergency acted by operation	PC and emergency released	10:55:00	11:10:00	
11	CHP	CC 54	trips in olr	reset	08:05:00	08:10:00	4 times
12	CHP	CC 58	olr acted	reset	10:50:00	10:55:00	
13	WT	SCO 1A(c)	mpcb tripped	made it on	08:10:00	08:15:00	
14	WT	CC 2 (C)	mpcb tripped	made it on	11:30:00	11:35:00	4 times
15	WT	CO 4(B)	mpcb tripped	made it on	10:10:00	10:15:00	