



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 18/06/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 49	SHOWING RED GLASS FUSE BLOWN IN CJB DUE TO PULL CHORD EARTH FAULT	PC FIELD WIRES REMOVE AND BY PASS GLASS FUSE REPLACED THAN OK	06:30:00	07:00:00	
2	OHP	TBS ON CO 20	LT NOT TAKING PLACE LT SELECTOR IN LOCAL MODE	KEPT IN REMOTE THAN OK	08:00:00	08:15:00	
3	OHP	BRC ON CO 8A	B/C OLR ACTED	RESET	08:15:00	08:30:00	
4	OHP	BRC ON CO 32	B/W 1 STOPPING ON ZS	B/W 1 ZS BY PASSED THAN OK	08:30:00	09:00:00	
5	OHP	RSCO 10A BELT DRIVE	OLR ACTED	RESET	13:00:00	13:15:00	
6	CHP	CC 51A	OLR ACTED	RESET	06:40:00	06:50:00	
7	CHP	CC 54	OLR ACTED	RESET	06:20:00	06:30:00	
8	CHP	CC 131	OLR ACTED (2TIMES)	RESET	11:30:00	12:40:00	
9	CHP	CC 39 SCR 7	SLEWING NOT WORKING BRAKE FAIL ACTED	RESET	09:00:00	09:30:00	
10	CHP	CC 36 SCR 1	LT NOT TAKING PLACE OVER VOLTAGE ACTED	RESET	09:00:00	09:30:00	
11	CHP	CC 33 SCR 4	LT O/T ACTED	RELEASED	09:30:00	09:45:00	
12	CHP	CC 40 SCR 6	SLEWING NOT WORKING LIMIT ACTED	INFORMED TO OPERATION	10:00:00	10:10:00	DUE TO MATERIAL JAMMING



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 18/06/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC 32 SCR 5	NO POWER HT FUSES BLOW 2NOS COUPLER OPENED SLIPRING SIDE CABLE OPENED MEGGER WAS DON	IN FORMED TO G SHIFT	09:00:00	10:30:00	
14	CHP	CC 40 SCR 6	B/C NOT RUNNING C/S MODULE PROBLEM	BY PASS	12:20:00	12:40:00	