



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 11/11/2025

Area: OHP

Equipment	Job
TBS-6 ON CO-20	LT vfd is changed and testing is done. 55kw spare vfd is shifted and kept at hvmcc-1