



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 26/08/2025

Incharge(s): Amit Roy,K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO-28	B/C NOT RUNNING CHECKED AND FOUND POWER MCCB TRIP	POWER MCCB MADE ON	04:00:00	04:15:00	
2	OHP	WOBR ON CO-29	LT NOT TAKING PLACE CHECKED AND FOUND M-4 OLR ACTED	OLR RESET DONE	04:15:00	04:30:00	
3	OHP	OC-1A (BELT DRIVE)	OLR ACTED	OLR RESET DONE	23:50:00	00:00:00	
4	OHP	CO-4	BELT KEPT IN LOCAL	TRIPPED ON OLR(3TIMES)	00:00:00	05:00:00	PRESENTLY IN LOCAL ONLY
5	CHP	CC-3 (BELT DRIVE)	OLR ACTED	OLR RESET DONE	05:10:00	05:20:00	
6	CHP	CC-58 ON TT	POSITION INDICATION NOT SHOWING CHECKED AND FOUND TT CABLE GOT CUT	TT CABLE RE JOINT DONE THAN OK	23:15:00	23:40:00	
7	CHP	CC-113	REPORT STOPPING ON ZSS	CHECKED AND FOUND BELT SNAPPED	05:05:00	05:15:00	INFORMED TO MECHANICAL
8	CHP	CC-39 SCR-7	B/C NOT MOVING	DISCHARGE CHUTE FOUND IN JAMMING CONDITION	23:40:00	00:00:00	INFORMED TO OPERATION
9	CHP	CC-125	REPORTED NOT HEALTHY	OLR TRIPPED.RESET DONE	00:00:00	00:10:00	
10	CHP	CC-44	REPORTED NOT HEALTHY	OLR ACTED.RESET DONE	01:10:00	01:20:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 26/08/2025

Incharge(s): Amit Roy, K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
11	CHP	CC-38 SCR-6	LT NOT WORKING	CHECKED AND FOUND MPCB1,2,3,6 TRIPPED DUE TO TRACK JAMMING.RESET DONE.	03:45:00	03:55:00	INFORMED TO OPERA TION
12	CHP	CC40 SCR-3	REPORTED LT NOT WORKING	CHECKED AND FOUND LT DRIVE TRIPPED.RESET DONE(2TIMES)	04:35:00 05:30:00	04:45:00 05:35:00	
13	CHP	CC-40 SCR3	SLEW NOT TAKING PLACE	LEFT LIMIT ACTED.RELEASED AND TESTED OKAY	03:00:00	03:15:00	