



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 06/02/2026

Shift: B

Incharge(s): Lal Singh,Lal Singh

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-13 CD	NOT MOVING CONTROL MCB OFF	MADE ON	18:15:00	18:25:00	
2	OHP	VF-23	TRIPPED ON OLR	RESET DONE	19:30:00	19:45:00	
3	OHP	BRC ON CO -28	CT DRIVE TRIPPED	RESET DONE	19:35:00	19:50:00	
4	OHP	CO-111	TRIPPED ON OLR	RESET DONE	21:30:00	21:35:00	
5	OHP	CO-8A	ZSS CABLE CUT	RE JOINT DONE	21:30:00	21:45:00	
6	CHP	CC-36 SCR-3	BC TRIPPED ON OLR	RESET DONE	16:50:00	17:00:00	
7	CHP	CC-51	TRIPPED ON OLR 7 TIMES	RESET DONE	17:05:00	18:30:00	
8	CHP	CC-58	TRIPPED ON OLR	RESET DONE	21:00:00	21:20:00	
9	CHP	RG-2 FG	TRIPPED 2 TIMES	RESET DONE	16:20:00	18:55:00	
10	WT	OP-9	COMMUNICATION PROBLEM	POWER RECYCLED	14:30:00	14:45:00	
11	WT	OP-4	ANTI COLLISION SENSOR PROBLEM	BYPASSED	17:00:00	17:10:00	
12	IOSA	TBS	ZSS CAGE STUCK	BYPASSED FOR RACK RELEASING THEN CAGE CHANGED	20:20:00	20:35:00	