



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 05/07/2025

Area: OHP

Equipment	Job
brc-4 on co-34	rtd cable to io rack checked, insulated at few places and restored temperature interlock in circuit.