



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 31/01/2026

Shift: A

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|------------------------------|--------------------------|-----------------------|----------|----------|---------|
| 1 | OHP | WBR ON CO 29 LT | DRIVE TRIPPED | RESET | 06:45:00 | 07:00:00 | |
| 2 | OHP | WBR ON CO 29 B/C | OLR ACTED | RESET | 07:50:00 | 08:00:00 | |
| 3 | OHP | WBR ON CO 25 LUFF | OLR ACTED | RESET | 09:05:00 | 09:15:00 | |
| 4 | OHP | BRC ON CO 29 LT and CT | SELECTOR SWITCH IN LOCAL | CHANGED TO REMOTE | 11:20:00 | 11:30:00 | |
| 5 | CHP | CC 28 | OLR ACTED | RESET | 08:45:00 | 08:50:00 | |
| 6 | CHP | SCR 1 ON CC 36 | PCRD CABLE ZIGZAG | WINDING DONE PROPERLY | 10:30:00 | 10:50:00 | |
| 7 | CHP | CC 216 | OLR ACTED | RESET | 11:15:00 | 11:25:00 | |
| 8 | CHP | CC 51 | FEEDING CONV OLR ACTED | RESET | 06:45:00 | 09:10:00 | 6 TIMES |
| 9 | CHP | CC 54 | OLR ACTED | RESET | 08:25:00 | 11:30:00 | 5 TIMES |