



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/11/2025

Shift: A

Incharge(s): Lal Singh,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO-8A	LT AND CT NOT WORKING	FAULT RESET IN HMI	10:45:00	11:15:00	
2	OHP	TT-2 ON BPIC -2	POSITION INDICATION NOT SHOW FOUND SENSOR PROBE PROBLEM	BYPASSED AT I/O RACK	07:20:00	07:35:00	
3	OHP	BRC ON CO-8A	REPORTED B/C NOT RUNNING FOUND ACB TRIP	MADE ON THAN OK	12:15:00	12:30:00	
4	OHP	WOBR ON CO-26	SLEW NOT WORKING DRIVE TRIP	DRIVE RESET DONE	12:55:00	13:05:00	
5	CHP	CC-54	TRIPPED ON OLR (3TIMES)	RESET DONE	07:30:00 07:45:00 08:00:00	07:35:00 07:50:00 08:05:00	
6	CHP	CC-51	MPD TRIP FEEDING CONVEYOR STOP	RESET DONE	09:55:00	10:00:00	
7	CHP	CC-117	TRIPPED ON OLR	RESET DONE	09:30:00	09:45:00	
8	CHP	CC-131	TRIPPED ON OLR	RESET DONE	12:55:00	13:00:00	
9	CHP	CC-132	TRIPPED ON OLR	RESET DONE	13:00:00	13:10:00	
10	CHP	CC-37 SCR-7	B/C TRIPPED ON OLR	RESET DONE	08:00:00	08:10:00	
11	CHP	CC-45	TRIPPED ON OLR(2TEMES)	RESET DONE	09:05:00 09:25:00	09:10:00 09:30:00	
12	CHP	CC-125	TRIPPED ON OLR (2TIMES)	RESET DONE	08:55:00 11:05:00	09:00:00 11:10:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/11/2025

Incharge(s): Lal Singh, K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC-34 SCR-2	REPORTED SLEW NOT WORKING FOUND 30, LIMIT ACTED DUE TO SLEW AREA MATERIAL JAMMING	AFTER CLEANING LIMIT RESET DONE THAN OK	11:40:00	12:10:00	
14	WT	OC-1A	TRIPPED ON OLR	RESET DONE	08:00:00	08:15:00	