



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 13/12/2025

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO-20	Reported LT not stopping	Stop PB damaged.Replaced	10:30:00	10:45:00	
2	OHP	BRC on CO-8A	Reported BW-2 not running	NO electrical problem found.	11:30:00	11:45:00	Informed to mechanical
3	OHP	CO-25	Reported tripped	OLR acted.Reset done	13:10:00	13:20:00	
4	OHP	WOBR on CO-26	Reported slew not taking place	Drive tripped.Reset done	07:40:00	07:50:00	
5	CHP	CC 40 SCR-2	Slew not taking place	Right limit acted.Jamming found.Informed to operation	08:26:00	08:45:00	Cleaning done and tested okay
6	CHP	CC 39 SCR-1	LT not taking place	Potentiometer connected properly and tested okay	11:01:00	11:20:00	
7	CHP	CC-51	MPD tripped	Feeding conveyor stopped.Reset done(13 times)	07:30:00	11:00:00	
8	CHP	Cc-22	Reported C/S acted	C/S acted due to over material flow.	10:30:00	10:45:00	Informed to operation